



BUR CAPSHEET SILICONE RESTORATION COATING SYSTEM

NOTES:

1. FIELD SEAMS SHOULD BE SEALED AND REINFORCED BY EITHER APPLYING SILICONE GEL OVER THE SEAM OR LACING THE SEAM WITH SILICONE AND POLYESTER FABRIC.
2. ALL ROOF TOP PENETRATIONS, DRAINS, SCUPPINS, FLASHINGS, EAVESGUTS, LAPWATER EDGE FLASHINGS ARE REQUIRED TO BE SEALED OR REINFORCED BY APPLYING SILICONE GEL OR LACING WITH SILICONE & POLYESTER FABRIC.
3. METACRYLIC ACRYLIC BLEED-BLOCK PRIMER PREVENTS THE ADHESION

SILICONE
COATING
SYSTEM

SCALE:

REV:

DATE:

BY:

09-29-17

CHALGILL

DATE:

A-01