



TPO SILICONE RESTORATION COATING SYSTEM

NOTES:

1. FIELD SEAMS SHOULD BE SEALED AND REINFORCED BY EITHER APPLYING SILICONE GEL OVER THE SEAM OR COURING THE SEAM WITH SILICONE AND POLYESTER FABRIC.
2. ALL ROOF TOP PENETRATIONS, DRAINS, SCUPPERS, FLASHINGS, SCHEDULE 40 PARAMETER EDGE FLASHING ARE REQUIRED TO BE SEALED OR REINFORCED BY APPLYING SILICONE GEL OR COURING WITH SILICONE & POLYESTER FABRIC.

SILICONE
COATING
SYSTEM

SEAL

REV:

REV NUMBER

DATE

08-28-17

CHALWELL

PROJECT

A-03