COOL ROOF RATING COUNCIL NOTIFICATION OF PRODUCT RATING



Notification Provided By: Cool Roof Rating Council 2435 N. Lombard St. Portland, OR 97217

Notification Provided To: Metacrylics 365 Obata Way, Gilroy, CA 95020

Product Brand: Metacrylics Product Type: Coating Product Model: Initial SRI: 110 Contractor Grade Acrylic White Company: 87 Metacrylics 3 Year SRI: Contact Name: Marc Rosenthal Slope Types: Low

Telephone: 9195982428 **Bright White** Color:



	Initial	Weathered
Solar Reflectance	0.87	0.71
Thermal Emittance	0.90	0.90
Rated Product ID	0660-0001	
Licensed Manufacturer	0660	
Classification	Standard Product	

Cool Roof Rating Council ratings are determined for a fixed set of conditions, and may not be appropriate for determining seasonal energy performance. The actual effect of solar reflectance and thermal emittance on building performance may vary.

Manufacturer of product stipulates that these ratings were determined in accordance with the applicable Cool Roof Rating Council procedures.

The Cool Roof Rating Council (CRRC), an ISO 17065 accredited organization, has reviewed the test results data provided by a CRRC-approved ISO 17025 testing laboratory and has determined this roofing product meets the requirements described in the ANSI/CRRC S100 Standard and the CRRC-1 Program Manual. This Notification of Rating is subject to all terms and conditions of the Licensee Agreement and the documents incorporated therein by reference. This document must be reproduced in its entirety.

The Notification of Rating certificate for the approved initial ratings is valid until an updated certificate is issued by the CRRC that includes the approved three-year aged ratings. The certificate with the approved three-year aged ratings is valid until either the CRRC or Licensee removes the product from the CRRC Rated Products Directory.

Technical Reviewer Melissa Riseman Ma

12/31/2017